



INTUMESCENT DOOR SEALS & HARDWARE PROTECTION KITS

Certificate number: IFCC 1686

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

Vanquish Hardware Protection Ltd

Fusion House
Downtown, Salisbury
Wiltshire. SP5 3FL
Tel: 01725 578020

Who manufacture the following intumescent seals & hardware protection kits:

FlexiFire

have satisfied the requirements of the SDP 20 Intumescent Seal & Hardware Protection Kits scheme v1.2. This includes the testing of products to **BS476: Part 22: 1987, BS EN 1634-1:2014, & BS EN 1634-1:2014+A1:2018**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate.

Initial Certification: 07 February 2022

Revised: 31 October 2024

Valid to: 06 February 2027

Issue number: 3

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



CERTIFICATE

The production intumescent seals & hardware protection kits are manufactured in accordance with assessment/ test reports referenced within the following table:

Product Description	Fire Rating	Assessment/Test Report
FlexiFire	EI30	WF345074/A Issue 2 WF530479 WF540202
FlexiFire	EI60	WF429674 WF524546/MRa WF513801/R TR20231222-003814 WF540203
FlexiFire	FD30, FD60	WF526507 AR1

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder’s responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

